


FRAME SIZE A5		
VOLTAGE	HP	KW
208/230	0.5-5	0.75-3.7
460/600	0.5-10	0.75-7.5

THE UNIT MUST BE INSTALLED VERTICALLY WITH THE MINIMUM FREE SPACE. UL NEMA TYPE 12 UNITS MAY BE MOUNTED SIDE BY SIDE WITH NO MINIMUM CLEARANCE.

- NOTICE -

THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF DAIKOS DRIVES. IT IS LOANED BY DAIKOS DRIVES SUBJECT TO THE CONDITIONS THAT IT AND THE INFORMATION EMBEDDED THEREIN SHALL BE USED ONLY FOR RECORD AND REFERENCE PURPOSES. IT SHALL NOT BE USED OR CAUSED TO BE USED IN ANY WAY PREJUDICIAL TO THE INTERESTS OF DAIKOS DRIVES. SHALL NOT BE REPRODUCED OR COPIED IN WHOLE OR IN PART OR DISCLOSED TO ANYONE WITHOUT THE DIRECT WRITTEN PERMISSION OF DAIKOS DRIVES AND SHALL BE RETURNED UPON REQUEST.

PRO-E ENTRY BY/DATE: MC 12/20/06	CHECKED BY/DATE: DA 02/07/07
-------------------------------------	---------------------------------

DESIGNED BY/DATE:	MFG. APPROVAL BY/DATE:
MD 12/20/00	MD 12/20/00

MFG. APPROVAL BY/DATE

MG 12/20/06
APPROVAL:

ENG. APPROVAL BY/DATE

TITLE:

DWG, REF, SUBMITTAL, A5-TIER I

LATEST E.C.N. NO. 3

E C.N. PRO-ENTRY BY/DATE:

PLOT SCALE:

PRO-E FILE:

SHEET:

DRAWING NO.:

DOI: 10.1002/for

REV.

DANFOSS DRIVES
4401 N. BELL SCHOOL RD., LOVES PARK, ILLINOIS 60111 USA

BELL SCHOOL RD. LOVES PARK, ILLINOIS 61111 USA
(815) 639-8600 FAX (815) 639-8000