



UNIT COOLING:  
 THE UNIT MUST BE INSTALLED VERTICALLY WITH THE MINIMUM FREE SPACE. ALL IP21/UL NEMA TYPE 1 AND IP54/NEMA TYPE 12 UNITS MAY BE MOUNTED SIDE BY SIDE WITH NO MINIMUM CLEARANCE.

- 1) 3X PLACE CONDUITS IN PRE-EXISTING CONDUIT HOLES
- 2) FOR NEMA TYPE 12 UNITS USE NEMA TYPE 12 CONDUITS AND HUBS

NOTICE:

THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF DANFOSS DRIVES. IT IS LOANED BY DANFOSS DRIVES SUBJECT TO THE CONDITIONS THAT IT AND THE INFORMATION CONTAINED THEREIN SHALL BE USED ONLY FOR RECORD AND REFERENCE PURPOSES. IT SHALL NOT BE USED OR CAUSED TO BE USED IN ANY MANNER THAT COULD BE REPRODUCED OR COPIED IN WHOLE OR IN PART OR DISCLOSED, EITHER ORALLY OR IN WRITING, WITHOUT THE EXPRESS WRITTEN PERMISSION OF DANFOSS DRIVES, AND SHALL BE RETURNED UPON REQUEST.

LATEST E.C.N. NO.:	E.C.N. PROJ. ENTRY BY/DATE:	PROJ. ENTRY BY/DATE:	CHECKED BY/DATE:	TITLE:
ECNSP07032	KD 04/04/07	KD 08/01/06	PD 09/03/07	DWG, REF. SUBMITTAL, BI-TIER 1, P650
		DESIGNED BY/DATE:	MFG. APPROVAL BY/DATE:	SHEET: 1 OF 1
		KD 08/01/06		DRAWING NO.: 17608471
		APPROVAL:	ENG. APPROVAL BY/DATE:	REV.: B
			5/7/07	
		PLAT. SCALE:	PROJ. FILE:	
		NONE	P404.BI.P650-2	



DANFOSS DRIVES  
 440 K. BELL SPONGE RD. JONES PARK, IL. 62450  
 (618) 531-5358 FAX (618) 531-5358