

Siemens  
EcoTech



SIMATIC S7-1500, CPU 1515-2 PN, central processing unit with work memory 1 MB for program and 4.5 MB for data, 1st interface: PROFINET IRT with 2-port switch, 2nd interface: PROFINET RT, 6 ns bit performance, SIMATIC Memory Card required - - approvals and certificates according to entry 109817466 at support.industry.siemens.com to be considered! - -

| General information  |  |
|--|--|
| Product type designation   | CPU 1515-2 PN  |
| HW functional status   | FS04   |
| Firmware version   | V4.0   |
| <ul style="list-style-type: none"> <li>FW update possible</li> </ul>                                     | Yes  |
| Product function   |  |
| <ul style="list-style-type: none"> <li>I&amp;M data</li> </ul>   | Yes; I&M0 to I&M3  |
| <ul style="list-style-type: none"> <li>Isochronous mode</li> </ul>                                       | Yes; Distributed and central; with minimum OB 6x cycle of 375 µs (distributed) and 1 ms (central)          |
| <ul style="list-style-type: none"> <li>SysLog</li> </ul>   | Yes  |
| Engineering with   |  |
| <ul style="list-style-type: none"> <li>STEP 7 TIA Portal configurable/integrated from version</li> </ul> | V20 (FW V4.0) / V18 (FW V3.0) or higher; configurable with older TIA Portal versions as 6ES7515-2AM02-0AB0 |
| Configuration control  |  |
| via dataset  | Yes  |
| Display  |  |
| Screen diagonal [cm]   | 6.1 cm   |
| Control elements   |  |
| Number of keys   | 8  |
| Mode buttons   | 2  |
| Supply voltage   |  |
| Rated value (DC)   | 24 V   |
| permissible range, lower limit (DC)  | 19.2 V   |
| permissible range, upper limit (DC)  | 28.8 V   |
| Reverse polarity protection  | Yes  |
| Mains buffering  |  |
| <ul style="list-style-type: none"> <li>Mains/voltage failure stored energy time</li> </ul>               | 5 ms   |
| <ul style="list-style-type: none"> <li>Repeat rate, min.</li> </ul>                                      | 1/s  |
| Input current  |  |
| Current consumption (rated value)  | 0.65 A   |
| Current consumption, max.  | 1.03 A   |
| Inrush current, max.   | 1.15 A; Rated value  |
| I <sup>2</sup> t   | 0.6 A <sup>2</sup> ·s  |
| Power  |  |
| Infed power to the backplane bus   | 12 W   |
| Power consumption from the backplane bus (balanced)  | 6.2 W  |
| Power loss   |  |

|   |   |
|---|---|
| Power loss, typ.                              | 3.6 W   |
| <b>Memory</b>                                 |   |
| Number of slots for SIMATIC memory card       | 1   |
| SIMATIC memory card required                  | Yes   |
| <b>Work memory</b>                            |   |
| • integrated (for program)                    | 1 Mbyte   |
| • integrated (for data)                       | 4.5 Mbyte   |
| <b>Load memory</b>                            |   |
| • Plug-in (SIMATIC Memory Card), max.         | 32 Gbyte  |
| <b>Backup</b>                                 |   |
| • maintenance-free                            | Yes   |
| <b>CPU processing times</b>                   |   |
| for bit operations, typ.                      | 6 ns  |
| for word operations, typ.                     | 7 ns  |
| for fixed point arithmetic, typ.              | 9 ns  |
| for floating point arithmetic, typ.           | 37 ns   |
| <b>CPU-blocks</b>                             |   |
| Number of elements (total)                    | 8 000; Blocks (OB, FB, FC, DB) and UDTs   |
| <b>DB</b>                                     |   |
| • Number range                                | 1 ... 60 999; subdivided into: number range that can be used by the user: 1 ... 59 999, and number range of DBs created via SFC 86: 60 000 ... 60 999 |
| • Size, max.                                  | 4.5 Mbyte; For DBs with absolute addressing, the max. size is 64 KB   |
| <b>FB</b>                                     |   |
| • Number range                                | 0 ... 65 535  |
| • Size, max.                                  | 1 Mbyte   |
| <b>FC</b>                                     |   |
| • Number range                                | 0 ... 65 535  |
| • Size, max.                                  | 1 Mbyte   |
| <b>OB</b>                                     |   |
| • Size, max.                                  | 1 Mbyte   |
| • Number of free cycle OBs                    | 100   |
| • Number of time alarm OBs                    | 20  |
| • Number of delay alarm OBs                   | 20  |
| • Number of cyclic interrupt OBs              | 20; With minimum OB 3x cycle of 250 µs  |
| • Number of process alarm OBs                 | 50  |
| • Number of DPV1 alarm OBs                    | 3   |
| • Number of isochronous mode OBs              | 2   |
| • Number of technology synchronous alarm OBs  | 2   |
| • Number of startup OBs                       | 100   |
| • Number of asynchronous error OBs            | 4   |
| • Number of synchronous error OBs             | 2   |
| • Number of diagnostic alarm OBs              | 1   |
| <b>Nesting depth</b>                          |   |
| • per priority class                          | 24  |
| <b>Counters, timers and their retentivity</b> |   |
| <b>S7 counter</b>                             |   |
| • Number                                      | 2 048   |
| <b>Retentivity</b>                            |   |
| — adjustable                                  | Yes   |
| <b>IEC counter</b>                            |   |
| • Number                                      | Any (only limited by the main memory)   |
| <b>Retentivity</b>                            |   |
| — adjustable                                  | Yes   |
| <b>S7 times</b>                               |   |
| • Number                                      | 2 048   |
| <b>Retentivity</b>                            |   |
| — adjustable                                  | Yes   |
| <b>IEC timer</b>                              |   |
| • Number                                      | Any (only limited by the main memory)   |
| <b>Retentivity</b>                            |   |
| — adjustable                                  | Yes   |

| Data areas and their retentivity                                   |   |
|--|---|
| Retentive data area (incl. timers, counters, flags), max.          | 512 kbyte; In total; available retentive memory for bit memories, timers, counters, DBs, and technology data (axes): 472 KB   |
| Extended retentive data area (incl. timers, counters, flags), max. | 4.5 Mbyte; When using PS 6 0W 24/48/60 V DC HF  |
| Flag   |   |
| • Size, max.   | 16 kbyte  |
| • Number of clock memories   | 8; 8 clock memory bit, grouped into one clock memory byte   |
| Data blocks  |   |
| • Retentivity adjustable   | Yes   |
| • Retentivity preset   | No  |
| Local data   |   |
| • per priority class, max.   | 64 kbyte; max. 16 KB per block  |
| Address area   |   |
| Number of IO modules   | 8 192; max. number of modules / submodules  |
| I/O address area   |   |
| • Inputs   | 32 kbyte; All inputs are in the process image   |
| • Outputs  | 32 kbyte; All outputs are in the process image  |
| per integrated IO subsystem  |   |
| — Inputs (volume)  | 8 kbyte   |
| — Outputs (volume)   | 8 kbyte   |
| per CM/CP  |   |
| — Inputs (volume)  | 8 kbyte   |
| — Outputs (volume)   | 8 kbyte   |
| Subprocess images  |   |
| • Number of subprocess images, max.                                | 32  |
| Hardware configuration   |   |
| Number of distributed IO systems                                   | 64; A distributed I/O system is characterized not only by the integration of distributed I/O via PROFINET or PROFIBUS communication modules, but also by the connection of I/O via AS-i master modules or links (e.g. IE/PB-Link) |
| Number of DP masters   |   |
| • Via CM   | 8; A maximum of 8 CMs/CPs (PROFIBUS, PROFINET, Ethernet) can be inserted in total   |
| Number of IO Controllers   |   |
| • integrated   | 2   |
| • Via CM   | 8; A maximum of 8 CMs/CPs (PROFIBUS, PROFINET, Ethernet) can be inserted in total   |
| Rack   |   |
| • Modules per rack, max.   | 32; CPU + 31 modules  |
| • Number of lines, max.  | 1   |
| PtP CM   |   |
| • Number of PtP CMs  | the number of connectable PtP CMs is only limited by the number of available slots  |
| Time of day  |   |
| Clock  |   |
| • Type   | Hardware clock  |
| • Backup time  | 6 wk; At 40 °C ambient temperature, typically   |
| • Deviation per day, max.  | 10 s; Typ.: 2 s   |
| Operating hours counter  |   |
| • Number   | 16  |
| Clock synchronization  |   |
| • supported  | Yes   |
| • to DP, master  | Yes; via PROFIBUS CM / CP   |
| • on DP, device  | Yes; via PROFIBUS CM / CP   |
| • in AS, master  | Yes   |
| • in AS, device  | Yes   |
| • on Ethernet via NTP  | Yes   |
| Interfaces   |   |
| Number of PROFINET interfaces                                      | 2   |
| 1. Interface   |   |
| Interface types  |   |
| • RJ 45 (Ethernet)   | Yes; X1   |
| • Number of ports  | 2   |

|   |  |
|---|--|
| • integrated switch   | Yes  |
| <b>Protocols</b>  |  |
| • IP protocol   | Yes; IPv4  |
| • PROFINET IO Controller  | Yes  |
| • PROFINET IO Device  | Yes  |
| • SIMATIC communication   | Yes  |
| • Open IE communication   | Yes; Optionally also encrypted   |
| • Web server  | Yes  |
| • Media redundancy  | Yes  |
| <b>PROFINET IO Controller</b>   |  |
| <b>Services</b>   |  |
| — Isochronous mode  | Yes  |
| — Direct data exchange  | Yes; Requirement: IRT and isochronous mode (MRPD optional)   |
| — IRT   | Yes  |
| — PROFINergy  | Yes; per user program  |
| — Prioritized startup   | Yes; Max. 32 PROFINET devices  |
| — Number of connectable IO Devices, max.                                      | 256; in total, up to 1024 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET  |
| — Of which IO devices with IRT, max.  | 64   |
| — Number of connectable IO Devices for RT, max.                               | 256  |
| — of which in line, max.  | 256  |
| — Number of IO Devices that can be simultaneously activated/deactivated, max. | 8; in total across all interfaces  |
| — Number of IO Devices per tool, max.   | 8  |
| — Updating times  | The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data |
| — PROFINET Security Class   | 1  |
| <b>Update time for IRT</b>  |  |
| — for send cycle of 250 µs  | 250 µs to 4 ms; Note: In the case of IRT with isochronous mode, the minimum update time of 375 µs of the isochronous OB is decisive                                    |
| — for send cycle of 500 µs  | 500 µs to 8 ms   |
| — for send cycle of 1 ms  | 1 ms to 16 ms  |
| — for send cycle of 2 ms  | 2 ms to 32 ms  |
| — for send cycle of 4 ms  | 4 ms to 64 ms  |
| — With IRT and parameterization of "odd" send cycles                          | Update time = set "odd" send clock (any multiple of 125 µs: 375 µs, 625 µs ... 3 875 µs)   |
| <b>Update time for RT</b>   |  |
| — for send cycle of 250 µs  | 250 µs to 128 ms   |
| — for send cycle of 500 µs  | 500 µs to 256 ms   |
| — for send cycle of 1 ms  | 1 ms to 512 ms   |
| — for send cycle of 2 ms  | 2 ms to 512 ms   |
| — for send cycle of 4 ms  | 4 ms to 512 ms   |
| <b>PROFINET IO Device</b>   |  |
| <b>Services</b>   |  |
| — Isochronous mode  | No   |
| — IRT   | Yes  |
| — PROFINergy  | Yes; per user program  |
| — Shared device   | Yes  |
| — Number of IO Controllers with shared device, max.                           | 4  |
| — activation/deactivation of I-devices  | Yes; per user program  |
| — Asset management record   | Yes; per user program  |
| — PROFINET Security Class   | SNMP Configuration and DCP Read Only   |
| <b>2. Interface</b>   |  |
| <b>Interface types</b>  |  |
| • RJ 45 (Ethernet)  | Yes; X2  |
| • Number of ports   | 1  |
| • integrated switch   | No   |
| <b>Protocols</b>  |  |
| • IP protocol   | Yes; IPv4  |
| • PROFINET IO Controller  | Yes  |
| • PROFINET IO Device  | Yes  |

|   |  |
|---|--|
| • SIMATIC communication   | Yes  |
| • Open IE communication   | Yes; Optionally also encrypted   |
| • Web server  | Yes  |
| • Media redundancy  | No   |
| <b>PROFINET IO Controller</b>   |  |
| <b>Services</b>   |  |
| — Isochronous mode  | No   |
| — Direct data exchange  | No   |
| — IRT   | No   |
| — PROFINergy  | Yes; per user program  |
| — Prioritized startup   | No   |
| — Number of connectable IO Devices, max.                                      | 32; in total, up to 1024 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET   |
| — Number of connectable IO Devices for RT, max.                               | 32   |
| — of which in line, max.  | 32   |
| — Number of IO Devices that can be simultaneously activated/deactivated, max. | 8; in total across all interfaces  |
| — Number of IO Devices per tool, max.   | 8  |
| — Updating times  | The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data |
| — PROFINET Security Class   | 1  |
| <b>Update time for RT</b>   |  |
| — for send cycle of 1 ms  | 1 ms to 512 ms   |
| <b>PROFINET IO Device</b>   |  |
| <b>Services</b>   |  |
| — Isochronous mode  | No   |
| — IRT   | No   |
| — PROFINergy  | Yes; per user program  |
| — Prioritized startup   | No   |
| — Shared device   | Yes  |
| — Number of IO Controllers with shared device, max.                           | 4  |
| — activation/deactivation of I-devices  | Yes; per user program  |
| — Asset management record   | Yes; per user program  |
| — PROFINET Security Class   | SNMP Configuration and DCP Read Only   |
| <b>Interface types</b>  |  |
| <b>RJ 45 (Ethernet)</b>   |  |
| • 100 Mbps  | Yes  |
| • Autonegotiation   | Yes  |
| • Autocrossing  | Yes  |
| • Industrial Ethernet status LED  | Yes  |
| <b>Protocols</b>  |  |
| PROFIsafe   | No   |
| <b>Number of connections</b>  |  |
| • Number of connections, max.   | 256; via integrated interfaces of the CPU and connected CPs / CMs  |
| • Number of connections reserved for ES/HMI/web                               | 10   |
| • Number of connections via integrated interfaces                             | 128  |
| • Number of S7 routing paths  | 16   |
| <b>Redundancy mode</b>  |  |
| • H-Sync forwarding   | Yes  |
| <b>Media redundancy</b>   |  |
| — Media redundancy  | only via 1st interface (X1)  |
| — MRP   | Yes; MRP Automanager according to IEC 62439-2 Edition 2.0, MRP Manager; MRP Client   |
| — MRP interconnection, supported  | Yes; as MRP ring node according to IEC 62439-2 Edition 3.0   |
| — MRPD  | Yes; Requirement: IRT  |
| — Switchover time on line break, typ.   | 200 ms; For MRP, bumpless for MRPD   |
| — Number of stations in the ring, max.  | 50   |
| <b>SIMATIC communication</b>  |  |
| • PG/OP communication   | Yes; encryption with TLS V1.3 pre-selected   |
| • S7 routing  | Yes  |
| • Data record routing   | Yes  |

|  |  |
|--|--|
| <ul style="list-style-type: none"> <li>• S7 communication, as server</li> </ul>  | Yes  |
| <ul style="list-style-type: none"> <li>• S7 communication, as client</li> </ul>  | Yes  |
| <ul style="list-style-type: none"> <li>• User data per job, max.</li> </ul>  | See online help (S7 communication, user data size)   |
| <b>Open IE communication</b>   |  |
| <ul style="list-style-type: none"> <li>• TCP/IP <ul style="list-style-type: none"> <li>— Data length, max.</li> <li>— several passive connections per port, supported</li> </ul> </li> <li>• ISO-on-TCP (RFC1006) <ul style="list-style-type: none"> <li>— Data length, max.</li> </ul> </li> <li>• UDP <ul style="list-style-type: none"> <li>— Data length, max.</li> <li>— UDP multicast</li> </ul> </li> <li>• DHCP</li> <li>• DNS</li> <li>• SNMP</li> <li>• DCP</li> <li>• LLDP</li> <li>• Encryption</li> </ul>   | Yes<br>64 kbyte<br>Yes<br>Yes<br>64 kbyte<br>Yes<br>2 kbyte; 1 472 bytes for UDP broadcast<br>Yes; max. 118 multicast circuits<br>Yes<br>Yes<br>Yes<br>Yes<br>Yes<br>Yes; Optional   |
| <b>Web server</b>  |  |
| <ul style="list-style-type: none"> <li>• HTTP</li> <li>• HTTPS</li> <li>• web API <ul style="list-style-type: none"> <li>— Number of sessions, max.</li> <li>— number of simultaneous HTTP calls, max.</li> <li>— HTTP request body, max.</li> </ul> </li> </ul>   | Yes; Standard and user pages<br>Yes; Standard and user pages<br>100<br>4<br>131 072 byte   |
| <b>OPC UA</b>  |  |
| <ul style="list-style-type: none"> <li>• Runtime license required</li> <li>• OPC UA Client <ul style="list-style-type: none"> <li>— Application authentication</li> <li>— Security policies</li> <li>— User authentication</li> <li>— Number of connections, max.</li> <li>— Number of nodes of the client interfaces, recommended max.</li> <li>— Number of elements for one call of OPC-UA-NodeGetHandleList/OPC-UA-ReadList/OPC-UA-WriteList, max.</li> <li>— Number of elements for one call of OPC-UA-NameSpaceGetIndexList, max.</li> <li>— Number of elements for one call of OPC-UA-MethodGetHandleList, max.</li> <li>— Number of simultaneous calls of the client instructions for session management, per connection, max.</li> <li>— Number of simultaneous calls of the client instructions for data access, per connection, max.</li> <li>— Number of registerable nodes, max.</li> <li>— Number of registerable method calls of OPC-UA-MethodCall, max.</li> <li>— Number of inputs/outputs when calling OPC-UA-MethodCall, max.</li> </ul> </li> <li>• OPC UA Server <ul style="list-style-type: none"> <li>— Application authentication</li> <li>— Security policies</li> <li>— User authentication</li> <li>— GDS support (certificate management)</li> <li>— Number of sessions, max.</li> <li>— Number of accessible variables, max.</li> <li>— Number of registerable nodes, max.</li> <li>— Number of subscriptions per session, max.</li> <li>— Sampling interval, min.</li> <li>— Publishing interval, min.</li> </ul> </li> </ul> | Yes; "Medium" license required<br>Yes; Data Access (registered Read/Write), Method Call<br>Yes<br>Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256<br>"anonymous" or by user name & password<br>10<br>2 000<br>300<br>20<br>100<br>1<br>5<br>5 000<br>100<br>20<br>Yes; data access (read, write, subscribe), method call, alarms & condition (A&C), custom address space, role-based access control<br>Yes<br>available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256, Aes128Sha256RsaOaep, Aes256Sha256RsaPss<br>"anonymous" or by user name & password<br>Yes<br>48<br>100 000<br>20 000<br>50<br>100 ms<br>100 ms |

|   |   |
|---|---|
| — Number of server methods, max.                                      | 50; max. 20 concurrently running jobs each for asynchronous instructions OPC-UA_ServerMethodPre and OPC-UA_ServerMethodPost       |
| — Number of inputs/outputs per server method, max.                    | 20  |
| — Number of monitored items, recommended max.                         | 4 000; for 1 s sampling interval and 1 s send interval  |
| — Number of server interfaces, max.                                   | 10 of each "Server interfaces" / "Companion specification" type and 20 of the type "Reference namespace"                          |
| — Number of nodes for user-defined server interfaces, max.            | 30 000  |
| • Alarms and Conditions   | Yes   |
| — Number of program alarms  | 200   |
| — Number of alarms for system diagnostics                             | 100   |
| <b>Further protocols</b>  |   |
| • MODBUS  | Yes; MODBUS TCP   |
| <b>S7 message functions</b>   |   |
| Number of login stations for message functions, max.                  | 64  |
| number of subscriptions, max.   | 500   |
| number of tags/attributes for subscriptions, max.                     | 8 000   |
| Program alarms  | Yes   |
| Number of configurable program messages, max.                         | 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH   |
| Number of loadable program messages in RUN, max.                      | 10 000  |
| Number of simultaneously active program alarms                        |   |
| • Number of program alarms  | 1 000   |
| • Number of alarms for system diagnostics                             | 200   |
| • Number of alarms for motion technology objects                      | 160   |
| <b>Test commissioning functions</b>                                   |   |
| Joint commission (Team Engineering)                                   | Yes; Parallel online access possible for up to 8 engineering systems  |
| Status block  | Yes; Up to 8 simultaneously (in total across all ES clients)  |
| Single step   | No  |
| Number of breakpoints   | 8   |
| Profiling   | Yes   |
| <b>Status/control</b>   |   |
| • Status/control variable   | Yes   |
| • Variables   | Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters  |
| • Number of variables, max.   |   |
| — of which status variables, max.                                     | 200; per job  |
| — of which control variables, max.                                    | 200; per job  |
| <b>Forcing</b>  |   |
| • Forcing   | Yes   |
| • Forcing, variables  | Peripheral inputs/outputs   |
| • Number of variables, max.   | 200   |
| <b>Diagnostic buffer</b>  |   |
| • present   | Yes   |
| • Number of entries, max.   | 3 200   |
| — of which powerfail-proof  | 500   |
| <b>Traces</b>   |   |
| • Number of configurable Traces                                       | 4   |
| • Memory size per trace, max.   | 512 kbyte   |
| <b>Interrupts/diagnostics/status information</b>                      |   |
| <b>Diagnostics indication LED</b>                                     |   |
| • RUN/STOP LED  | Yes   |
| • ERROR LED   | Yes   |
| • MAINT LED   | Yes   |
| • STOP ACTIVE LED   | Yes   |
| • Connection display LINK TX/RX                                       | Yes   |
| <b>Supported technology objects</b>                                   |   |
| Motion Control  | Yes; Note: The number of technology objects affects the cycle time of the PLC program; selection guide via the TIA Selection Tool |
| • Number of available Motion Control resources for technology objects | 2 400   |
| • Required Motion Control resources                                   |   |
| — per speed-controlled axis   | 40  |

|  |  |
|--|--|
| — per positioning axis   | 80   |
| — per synchronous axis   | 160  |
| — per external encoder   | 80   |
| — per output cam   | 20   |
| — per cam track  | 160  |
| — per probe  | 40   |
| • Positioning axis   |  |
| — Number of positioning axes at motion control cycle of 4 ms (typical value) | 11   |
| — Number of positioning axes at motion control cycle of 8 ms (typical value) | 20   |
| Controller   |  |
| • PID_Compact  | Yes; Universal PID controller with integrated optimization   |
| • PID_3Step  | Yes; PID controller with integrated optimization for valves  |
| • PID-Temp   | Yes; PID controller with integrated optimization for temperature                                   |
| Counting and measuring   |  |
| • High-speed counter   | Yes  |
| <b>Standards, approvals, certificates</b>                                    |  |
| Siemens Eco Profile (SEP)  | Siemens EcoTech  |
| <b>Ecological footprint</b>  |  |
| • environmental product declaration  | Yes  |
| <b>Global warming potential</b>  |  |
| — global warming potential, (total) [CO2 eq]                                 | 100 kg   |
| — global warming potential, (during production) [CO2 eq]                     | 25.8 kg  |
| — global warming potential, (during operation) [CO2 eq]                      | 75.2 kg  |
| — global warming potential, (after end of life cycle) [CO2 eq]               | -0.83 kg   |
| <b>product functions / security / header</b>                                 |  |
| PROFINET Security Class  | 1  |
| signed firmware update   | Yes  |
| Secure Boot  | Yes  |
| safely removing data   | Yes  |
| <b>Ambient conditions</b>  |  |
| <b>Ambient temperature during operation</b>                                  |  |
| • horizontal installation, min.  | -30 °C; No condensation  |
| • horizontal installation, max.  | 60 °C; Display: 50 °C, at an operating temperature of typically 50 °C, the display is switched off |
| • vertical installation, min.  | -30 °C; No condensation  |
| • vertical installation, max.  | 40 °C; Display: 40 °C, at an operating temperature of typically 40 °C, the display is switched off |
| <b>Ambient temperature during storage/transportation</b>                     |  |
| • min.   | -40 °C   |
| • max.   | 70 °C  |
| <b>Altitude during operation relating to sea level</b>                       |  |
| • Installation altitude above sea level, max.                                | 5 000 m; Restrictions for installation altitudes > 2 000 m, see manual                             |
| <b>configuration / header</b>  |  |
| <b>configuration / programming / header</b>                                  |  |
| <b>Programming language</b>  |  |
| — LAD  | Yes  |
| — FBD  | Yes  |
| — STL  | Yes  |
| — SCL  | Yes  |
| — CFC  | Yes  |
| — GRAPH  | Yes  |
| <b>Know-how protection</b>   |  |
| • User program protection/password protection                                | Yes  |
| • Copy protection  | Yes  |
| • Block protection   | Yes  |
| <b>Access protection</b>   |  |
| • protection of confidential configuration data                              | Yes  |
| • Password for display   | Yes  |

- Protection level: Write protection Yes
- Protection level: Read/write protection Yes
- Protection level: Write protection for Failsafe No
- Protection level: Complete protection Yes
- User administration Yes; device-wide and centralized
- Number of users 100
- Number of groups 100
- Number of roles 50

|  |                               |
|--|-------------------------------|
| programming / cycle time monitoring / header |                               |
| • lower limit                                | adjustable minimum cycle time |
| • upper limit                                | adjustable maximum cycle time |

| Dimensions |        |
|------------|--------|
| Width      | 70 mm  |
| Height     | 147 mm |
| Depth      | 129 mm |

| Weights         |       |
|-----------------|-------|
| Weight, approx. | 456 g |

| Classifications |        |         |                |
|-----------------|--------|---------|----------------|
|                 |        | Version | Classification |
|                 | eClass | 14      | 27-24-22-07    |
|                 | eClass | 12      | 27-24-22-07    |
|                 | eClass | 9.1     | 27-24-22-07    |
|                 | eClass | 9       | 27-24-22-07    |
|                 | eClass | 8       | 27-24-22-07    |
|                 | eClass | 7.1     | 27-24-22-07    |
|                 | eClass | 6       | 27-24-22-07    |
|                 | ETIM   | 9       | EC000236       |
|                 | ETIM   | 8       | EC000236       |
|                 | ETIM   | 7       | EC000236       |
|                 | IDEA   | 4       | 3565           |
|                 | UNSPSC | 15      | 32-15-17-05    |

**Approvals / Certificates**

**General Product Approval**



[Manufacturer Declaration](#)



[Miscellaneous](#)



**General Product Approval**      **For use in hazardous locations**

[KC](#)



[FM](#)



[EM](#)



**For use in hazardous locations**      **Test Certificates**      **Marine / Shipping**

[Type Examination Certificate](#)



[Miscellaneous](#)

[Type Test Certificates/Test Report](#)



**Marine / Shipping**



[NK / Nippon Kaiji Kyokai](#)



[CCS \(China Classification Society\)](#)



other

Environment

[PROFINET](#)



Siemens  
EcoTech



last modified:

12/19/2024